SIEMENS

Data sheet

Im

6EP1334-1LD00

SITOP PSU100D/1AC/24VDC/12.5A

********** spare part ******** PSU100D 24 V/12.5 A stabilized power supply input: 100-240 V AC output: 24 V DC/12.5 A



Input	
type of the power supply network	1-phase AC
supply voltage at AC	
minimum rated value	100 V
maximum rated value	240 V
● initial value	85 V
• full-scale value	264 V
design of input wide range input	Yes
operating condition of the mains buffering	at Vin = 115/230 V
buffering time for rated value of the output current in the event of power failure minimum	15 ms
operating condition of the mains buffering	at Vin = 115/230 V
line frequency	
• 1 rated value	50 Hz
• 2 rated value	60 Hz
line frequency	47 63 Hz
input current	
 at rated input voltage 100 V 	4 A
 at rated input voltage 240 V 	2 A
current limitation of inrush current at 25 °C maximum	60 A
I2t value maximum	1.1 A ² ·s
fuse protection type	internal
• in the feeder	Recommended miniature circuit breaker: from 10 A characteristic C or from 16 A characteristic B
Output	
voltage curve at output	Controlled, isolated DC voltage
output voltage at DC rated value	24 V
output voltage	
 at output 1 at DC rated value 	24 V
relative overall tolerance of the voltage	2 %
relative control precision of the output voltage	
 on slow fluctuation of input voltage 	0.5 %
on slow fluctuation of ohm loading	0.5 %
residual ripple	
• maximum	100 mV
voltage peak	
• maximum	100 mV
adjustable output voltage	22 28 V
product function output voltage adjustable	Yes
type of output voltage setting	via potentiometer
display version for normal operation	Green LED for 24 V OK

type of signal at output	
type of signal at output	- Overshoot of Vout < 2 %
behavior of the output voltage when switching on response delay maximum	Overshoot of Vout < 2 %
voltage increase time of the output voltage	15
maximum	30 ms
output current	
rated value	12.5 A
rated range	0 12.5 A; +50 +70 °C: Derating 2.5%/K
supplied active power typical	300 W
product feature	
bridging of equipment	Yes
number of parallel-switched equipment resources for increasing	2
the power	2
Efficiency	
efficiency in percent	86 %
power loss [W]	
 at rated output voltage for rated value of the output current typical 	48 W
Closed-loop control	
relative control precision of the output voltage with rapid	0.5 %
fluctuation of the input voltage by +/- 15% typical	
relative control precision of the output voltage load step of resistive load 50/100/50 % typical	5 %
Protection and monitoring	
design of the overvoltage protection	< 35 V
• typical	15 A
property of the output short-circuit proof	Yes
design of short-circuit protection	Electronic shutdown, automatic restart
enduring short circuit current RMS value	
• typical	15 A
display version for overload and short circuit	-
Safety	
galvanic isolation between input and output	Yes
galvanic isolation	Safety extra low output voltage Vout according to EN 60950-1
operating resource protection class	Class I
leakage current	
• maximum	3.5 mA
• typical	1 mA
protection class IP	IP20
Approvals	
certificate of suitability	
• CE marking	Yes
• UL approval	
- OE approva	Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus (UL 60950-1, CSA C22.2 No. 60950-1), File E151273
CSA approval	60950-1, CSA C22.2 No. 60950-1), File E151273 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus (UL
CSA approval	60950-1, CSA C22.2 No. 60950-1), File E151273 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus (UL 60950-1, CSA C22.2 No. 60950-1), File E151273
	60950-1, CSA C22.2 No. 60950-1), File E151273 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus (UL 60950-1, CSA C22.2 No. 60950-1), File E151273 No
 CSA approval cCSAus, Class 1, Division 2 ATEX 	60950-1, CSA C22.2 No. 60950-1), File E151273 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus (UL 60950-1, CSA C22.2 No. 60950-1), File E151273
 CSA approval cCSAus, Class 1, Division 2 	60950-1, CSA C22.2 No. 60950-1), File E151273 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus (UL 60950-1, CSA C22.2 No. 60950-1), File E151273 No
CSA approval cCSAus, Class 1, Division 2 ATEX certificate of suitability	60950-1, CSA C22.2 No. 60950-1), File E151273 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus (UL 60950-1, CSA C22.2 No. 60950-1), File E151273 No No
CSA approval cCSAus, Class 1, Division 2 ATEX certificate of suitability IECEx NEC Class 2	60950-1, CSA C22.2 No. 60950-1), File E151273 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus (UL 60950-1, CSA C22.2 No. 60950-1), File E151273 No No
CSA approval cCSAus, Class 1, Division 2 ATEX certificate of suitability IECEx	60950-1, CSA C22.2 No. 60950-1), File E151273 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus (UL 60950-1, CSA C22.2 No. 60950-1), File E151273 No No No
CSA approval cCSAus, Class 1, Division 2 ATEX certificate of suitability IECEx NEC Class 2 ULhazloc approval	60950-1, CSA C22.2 No. 60950-1), File E151273 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus (UL 60950-1, CSA C22.2 No. 60950-1), File E151273 No No No No
CSA approval cCSAus, Class 1, Division 2 ATEX certificate of suitability IECEx NEC Class 2 ULhazloc approval FM registration	60950-1, CSA C22.2 No. 60950-1), File E151273 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus (UL 60950-1, CSA C22.2 No. 60950-1), File E151273 No No No No No
CSA approval cCSAus, Class 1, Division 2 ATEX certificate of suitability IECEx NEC Class 2 ULhazloc approval FM registration type of certification CB-certificate	60950-1, CSA C22.2 No. 60950-1), File E151273 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus (UL 60950-1, CSA C22.2 No. 60950-1), File E151273 No No No No No
CSA approval cCSAus, Class 1, Division 2 ATEX certificate of suitability IECEx NEC Class 2 ULhazloc approval FM registration type of certification CB-certificate certificate of suitability	60950-1, CSA C22.2 No. 60950-1), File E151273 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus (UL 60950-1, CSA C22.2 No. 60950-1), File E151273 No No No No No Yes
CSA approval cCSAus, Class 1, Division 2 ATEX certificate of suitability IECEx NEC Class 2 ULhazloc approval FM registration type of certification CB-certificate certificate of suitability EAC approval	60950-1, CSA C22.2 No. 60950-1), File E151273 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus (UL 60950-1, CSA C22.2 No. 60950-1), File E151273 No No No No Yes Yes
CSA approval cCSAus, Class 1, Division 2 ATEX certificate of suitability IECEx NEC Class 2 ULhazloc approval FM registration type of certification CB-certificate certificate of suitability EAC approval certificate of suitability shipbuilding approval	60950-1, CSA C22.2 No. 60950-1), File E151273 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus (UL 60950-1, CSA C22.2 No. 60950-1), File E151273 No No No No No Yes Yes No
CSA approval ccSAus, Class 1, Division 2 ATEX certificate of suitability IECEx NEC Class 2 ULhazloc approval FM registration type of certification CB-certificate certificate of suitability EAC approval certificate of suitability shipbuilding approval shipbuilding approval	60950-1, CSA C22.2 No. 60950-1), File E151273 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus (UL 60950-1, CSA C22.2 No. 60950-1), File E151273 No No No No No Yes Yes No
CSA approval ccSAus, Class 1, Division 2 ATEX certificate of suitability IECEx NEC Class 2 ULhazloc approval FM registration type of certification CB-certificate certificate of suitability EAC approval certificate of suitability shipbuilding approval shipbuilding approval Marine classification association	60950-1, CSA C22.2 No. 60950-1), File E151273 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus (UL 60950-1, CSA C22.2 No. 60950-1), File E151273 No No No No No Yes Yes No
CSA approval cCSAus, Class 1, Division 2 ATEX certificate of suitability IECEx NEC Class 2 ULhazloc approval FM registration type of certification CB-certificate certificate of suitability EAC approval certificate of suitability EAC approval certificate of suitability shipbuilding approval shipbuilding approval Marine classification association American Bureau of Shipping Europe Ltd. (ABS)	60950-1, CSA C22.2 No. 60950-1), File E151273 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus (UL 60950-1, CSA C22.2 No. 60950-1), File E151273 No No No No No Yes Yes No -

 Lloyds Register of Shipping (LRS) 	No
 Nippon Kaiji Kyokai (NK) 	No
EMC	
standard	
 for emitted interference 	EN 55022 Class B
 for mains harmonics limitation 	EN 61000-3-2
 for interference immunity 	EN 61000-6-2
environmental conditions	
ambient temperature	
 during operation 	-10 +70 °C; with forced convection (ventilator)
 during transport 	-40 +85 °C
 during storage 	-40 +85 °C
Mechanics	
type of electrical connection	screw-type terminals
• at input	L, N, PE: 1 screw terminal each for 0.5 1.3 mm ² single-core/finely stranded
 at output 	+, -: 2 screw terminals each for 0.5 1.3 mm ²
 for auxiliary contacts 	-
width of the enclosure	105 mm
height of the enclosure	199 mm
depth of the enclosure	41 mm
required spacing	
• top	20 mm
• bottom	0 mm
• left	20 mm
● right	20 mm
net weight	0.81 kg
fastening method	Wall mounting
other information	Specifications at rated input voltage and ambient temperature +25 °C (unless otherwise specified)

